

ATTENTION: Chevron Station Manager

THIS REPORT IS TO BE SIGNED BY YOU WHEN THE WORK IS COMPLETED
THIS FORM IS TO BE GIVEN BACK TO CONTRACTOR



Chevron
Facility Maintenance Department

Contractor Work Report

**DOOR
REPAIR**
COMPLETED

CONTRACTING FIRM: **TITAN DOORS**

Titan Doors Job # P6053	Order # NCM74-NCA58954	Vendor # New
--------------------------------	-------------------------------	---------------------

Requested Service URGENT door repair; "Storefront Automatic Slider" biparting automatic slider, approx 14'x8', with faulty operation. Stanley brand noted. Door operation falls during midday heat, south facing entrance with 2-way traffic. Exterior Sensors suspect to heat failure. Others cleaned lens, no result. Chevron Corp request demo slider & install new storefront with pair manual doors & maglock security. Station open 7 days - 24 hours. Determine new materials ASAP. Security & Safety concerns.

Job Progress Report 6-2 In progress, site visit ASAP. Titan Doors researched temporary repair options; install new Optex exterior sensor (more tolerant & reliable to heat concerns), or swap existing interior sensor to exterior as Temp Solution, test. 6-5 Chevron pre-approved new Optex sensor as required. 6-5 Ordered new sensor parts EXPEDITED. 6-7 Foreman Tech on site, observed door operation stopped as sun shined over Bldg onto door sensor. We provided service to repair; removed faulty BEA exterior sensor, installed 1-new Optex microwave scan sensor on exterior of slider and adjusted scan range. Found hold open switch wired incorrectly; we corrected wiring of Hold Open switch for proper operation. Track cleaned of debris for proper 100% close. Found 2 PT lock mechanical binding (locks slider panels to breakout panels for proper security); we adjusted lock rods for smoother lock-unlock. Found rollers worn from use. New rollers suggested next time. We observed operation, tested OK. Automatic slider repaired for extended useful life. 6-7 Job Completed. 6-8 & 6-9 Titan Doors monitored reliable door operation, per site Mgrs, working good through midday heat. 6-9 Glass Tech sched on site to measure for new manual storefront materials. (Request by Chevron Corp). 6-9 Repair Job & follow up Completed.

Additional Inquiries on Job Status or Material ...please call USA Toll Free 877-98-TITAN

Job Site: Chevron # 95266 1250 Westwood Street Willows CA 95988 Contact: Della Ramsey, Station Manager Contact: Olivia Parrish, Co-Mgr., Holly or Kim, Cashiers Manager's Signature: <i>Della Ramsey</i> Dated: <i>6-09-06</i> Initials: <i>DR</i>	*Titan Doors Authorized Suppliers Include : Capitol Door Service Commercial Glass Upon Final Completion Please Sign, Date and FAX Return To: Titan Doors Call Service Center Attn: Paul Loverme USA Toll Free FAX 866-398-4826
--	--

TO BE COMPLETED BY STORE MANAGEMENT:	YES	NO
1. Was quality of work satisfactory?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Did our suppliers cooperate with you satisfactorily?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Was clean up after work completion of work satisfactory?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4. Did our suppliers complete all work that was requested?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5. Overall Performance?	Poor	Good
		Excellent

Chevron Stations, Inc. # 1702
Chevron Facility # 95266
1250 W. Wood St
Willows, CA 95988
Phone(530) 934-5802

Della Ramsey